

广州科城环保科技有限公司污染源监测数据公开（在线自动监测）

监测点位名称：工业废水排放口

监测时间：2020年3月

监测时间		pH值	标准限值	化学需氧量 (mg/l)	标准限值 (mg/l)	监测结果说明
2020/3/1	1:00:00	8.07	6-9	0	90	达标
2020/3/1	5:00:00	8.12	6-9	0	90	达标
2020/3/1	9:00:00	8.21	6-9	0	90	达标
2020/3/1	13:00:00	8.25	6-9	0	90	达标
2020/3/1	17:00:00	8.29	6-9	0	90	达标
2020/3/2	21:00:00	8.33	6-9	0	90	达标
2020/3/2	1:00:00	8.36	6-9	0	90	达标
2020/3/2	5:00:00	8.4	6-9	0	90	达标
2020/3/2	9:00:00	8.55	6-9	19.6	90	达标
2020/3/2	13:00:00	7.45	6-9	64	90	达标
2020/3/2	17:00:00	7.49	6-9	0	90	达标
2020/3/3	21:00:00	7.57	6-9	0	90	达标
2020/3/3	1:00:00	7.69	6-9	0	90	达标
2020/3/3	5:00:00	7.84	6-9	0	90	达标
2020/3/3	9:00:00	8.07	6-9	58.5	90	达标
2020/3/3	13:00:00	7.58	6-9	31.4	90	达标
2020/3/3	17:00:00	7.42	6-9	55.8	90	达标
2020/3/4	21:00:00	7.09	6-9	60.8	90	达标
2020/3/4	1:00:00	8.58	6-9	3.6	90	达标
2020/3/4	5:00:00	8.46	6-9	2.2	90	达标
2020/3/4	9:00:00	7.99	6-9	62.5	90	达标
2020/3/4	13:00:00	8.04	6-9	63.8	90	达标
2020/3/4	17:00:00	8.05	6-9	0	90	达标
2020/3/5	21:00:00	8.05	6-9	0	90	达标
2020/3/5	1:00:00	8.06	6-9	0	90	达标
2020/3/5	5:00:00	8.06	6-9	0	90	达标
2020/3/5	9:00:00	7.98	6-9	35	90	达标
2020/3/5	13:00:00	8.28	6-9	43.5	90	达标
2020/3/5	17:00:00	8.06	6-9	58.3	90	达标
2020/3/6	21:00:00	8.91	6-9	6	90	达标
2020/3/6	1:00:00	8.85	6-9	0	90	达标
2020/3/6	5:00:00	8.81	6-9	1.1	90	达标
2020/3/6	9:00:00	8.62	6-9	5.2	90	达标
2020/3/6	13:00:00	8.08	6-9	50.3	90	达标
2020/3/6	17:00:00	8.27	6-9	71	90	达标
2020/3/7	21:00:00	7.94	6-9	70.5	90	达标
2020/3/7	1:00:00	7.98	6-9	0	90	达标
2020/3/7	5:00:00	8.02	6-9	0	90	达标
2020/3/7	9:00:00	8.03	6-9	0	90	达标
2020/3/7	13:00:00	8.03	6-9	0	90	达标
2020/3/7	17:00:00	8.03	6-9	0	90	达标
2020/3/8	21:00:00	8.03	6-9	0	90	达标

2020/3/8	1:00:00	8.02	6-9	0	90	达标
2020/3/8	5:00:00	7.99	6-9	0	90	达标
2020/3/8	9:00:00	7.92	6-9	0	90	达标
2020/3/8	13:00:00	7.81	6-9	0	90	达标
2020/3/8	17:00:00	7.76	6-9	0	90	达标
2020/3/9	21:00:00	7.79	6-9	0	90	达标
2020/3/9	1:00:00	7.8	6-9	0	90	达标
2020/3/9	5:00:00	7.81	6-9	0	90	达标
2020/3/9	9:00:00	7.58	6-9	64.5	90	达标
2020/3/9	13:00:00	7.93	6-9	0.4	90	达标
2020/3/9	17:00:00	7.98	6-9	45.3	90	达标
2020/3/10	21:00:00	8.17	6-9	50.8	90	达标
2020/3/10	1:00:00	7.68	6-9	57.3	90	达标
2020/3/10	5:00:00	8.23	6-9	60	90	达标
2020/3/10	9:00:00	7.53	6-9	64.3	90	达标
2020/3/10	13:00:00	7.78	6-9	57.8	90	达标
2020/3/10	17:00:00	8.15	6-9	54	90	达标
2020/3/11	21:00:00	7.52	6-9	37	90	达标
2020/3/11	1:00:00	7.21	6-9	40.3	90	达标
2020/3/11	5:00:00	7.41	6-9	64.5	90	达标
2020/3/11	9:00:00	7.19	6-9	50.8	90	达标
2020/3/11	13:00:00	8.4	6-9	18.1	90	达标
2020/3/11	17:00:00	8.53	6-9	54.8	90	达标
2020/3/12	21:00:00	7.68	6-9	59	90	达标
2020/3/12	1:00:00	7.47	6-9	59.8	90	达标
2020/3/12	5:00:00	7.23	6-9	69.5	90	达标
2020/3/12	9:00:00	8.67	6-9	33.8	90	达标
2020/3/12	13:00:00	7.84	6-9	42.5	90	达标
2020/3/12	17:00:00	7.86	6-9	35.4	90	达标
2020/3/13	21:00:00	7.79	6-9	42.3	90	达标
2020/3/13	1:00:00	7.44	6-9	61.3	90	达标
2020/3/13	5:00:00	7.93	6-9	66	90	达标
2020/3/13	9:00:00	7.98	6-9	58.8	90	达标
2020/3/13	13:00:00	7.62	6-9	37	90	达标
2020/3/13	17:00:00	7.65	6-9	61.5	90	达标
2020/3/14	21:00:00	8.04	6-9	65.5	90	达标
2020/3/14	1:00:00	8.28	6-9	65.5	90	达标
2020/3/14	5:00:00	7.68	6-9	8.4	90	达标
2020/3/14	9:00:00	7.41	6-9	64	90	达标
2020/3/14	13:00:00	7.92	6-9	58.5	90	达标
2020/3/14	17:00:00	7.06	6-9	41.8	90	达标
2020/3/15	21:00:00	7.21	6-9	59.8	90	达标
2020/3/15	1:00:00	7.93	6-9	59.8	90	达标
2020/3/15	5:00:00	7.84	6-9	35.3	90	达标
2020/3/15	9:00:00	7.56	6-9	71	90	达标
2020/3/15	13:00:00	7.83	6-9	54.8	90	达标

2020/3/15	17:00:00	7.64	6-9	57.8	90	达标
2020/3/16	21:00:00	8.16	6-9	55.5	90	达标
2020/3/16	1:00:00	7.69	6-9	40.3	90	达标
2020/3/16	5:00:00	7.75	6-9	36.8	90	达标
2020/3/16	9:00:00	7.92	6-9	58	90	达标
2020/3/16	13:00:00	6.77	6-9	65.5	90	达标
2020/3/16	17:00:00	6.73	6-9	58.3	90	达标
2020/3/17	21:00:00	7.74	6-9	45.5	90	达标
2020/3/17	1:00:00	6.84	6-9	60.5	90	达标
2020/3/17	5:00:00	7.61	6-9	54.8	90	达标
2020/3/17	9:00:00	7.2	6-9	56.3	90	达标
2020/3/17	13:00:00	7.56	6-9	39.3	90	达标
2020/3/18	17:00:00	7.54	6-9	30.6	90	达标
2020/3/18	21:00:00	7.62	6-9	29.5	90	达标
2020/3/18	1:00:00	6.68	6-9	64.5	90	达标
2020/3/18	5:00:00	7.8	6-9	61.5	90	达标
2020/3/18	9:00:00	7.64	6-9	29.9	90	达标
2020/3/19	13:00:00	7.03	6-9	63.8	90	达标
2020/3/19	17:00:00	7.68	6-9	61.3	90	达标
2020/3/19	21:00:00	7.64	6-9	61	90	达标
2020/3/19	1:00:00	6.78	6-9	61	90	达标
2020/3/19	5:00:00	7.09	6-9	33.5	90	达标
2020/3/19	9:00:00	7.12	6-9	66	90	达标
2020/3/20	13:00:00	7.93	6-9	24.9	90	达标
2020/3/20	17:00:00	8.07	6-9	62.3	90	达标
2020/3/20	21:00:00	7.96	6-9	57.8	90	达标
2020/3/20	1:00:00	8.16	6-9	32.8	90	达标
2020/3/20	5:00:00	8.03	6-9	13.4	90	达标
2020/3/20	9:00:00	7.6	6-9	57.8	90	达标
2020/3/21	13:00:00	7.92	6-9	29	90	达标
2020/3/21	17:00:00	7.69	6-9	60.3	90	达标
2020/3/21	21:00:00	8.12	6-9	42.8	90	达标
2020/3/21	1:00:00	7.9	6-9	61.3	90	达标
2020/3/21	5:00:00	7.72	6-9	54.8	90	达标
2020/3/21	9:00:00	7.79	6-9	38.5	90	达标
2020/3/22	13:00:00	7.66	6-9	57.3	90	达标
2020/3/22	17:00:00	6.29	6-9	56.8	90	达标
2020/3/22	21:00:00	7.53	6-9	60.5	90	达标
2020/3/22	1:00:00	8.01	6-9	45	90	达标
2020/3/22	5:00:00	7.37	6-9	41.5	90	达标
2020/3/22	9:00:00	7.45	6-9	60	90	达标
2020/3/23	13:00:00	7.86	6-9	53	90	达标
2020/3/23	17:00:00	7.89	6-9	53.3	90	达标
2020/3/23	21:00:00	8.71	6-9	38.5	90	达标
2020/3/23	1:00:00	8.72	6-9	39.8	90	达标
2020/3/23	5:00:00	8.11	6-9	63.3	90	达标

2020/3/23	9:00:00	8.44	6-9	62.3	90	达标
2020/3/24	13:00:00	8.12	6-9	63.3	90	达标
2020/3/24	17:00:00	7.72	6-9	40.3	90	达标
2020/3/24	21:00:00	7.71	6-9	36.8	90	达标
2020/3/24	1:00:00	7.96	6-9	54.8	90	达标
2020/3/24	5:00:00	7.87	6-9	17.3	90	达标
2020/3/24	9:00:00	7.6	6-9	31.9	90	达标
2020/3/25	13:00:00	7.74	6-9	67.5	90	达标
2020/3/25	17:00:00	7.4	6-9	54.5	90	达标
2020/3/25	21:00:00	7.17	6-9	56.8	90	达标
2020/3/25	1:00:00	7.79	6-9	55.5	90	达标
2020/3/25	5:00:00	7.42	6-9	64	90	达标
2020/3/25	9:00:00	7.58	6-9	59.8	90	达标
2020/3/26	13:00:00	7.47	6-9	57	90	达标
2020/3/26	17:00:00	8.03	6-9	55	90	达标
2020/3/26	21:00:00	6.57	6-9	56.3	90	达标
2020/3/26	1:00:00	7.68	6-9	51	90	达标
2020/3/26	5:00:00	7.68	6-9	11.9	90	达标
2020/3/26	9:00:00	6.72	6-9	55.5	90	达标
2020/3/27	13:00:00	7.78	6-9	27.1	90	达标
2020/3/27	17:00:00	7.69	6-9	15.1	90	达标
2020/3/27	21:00:00	7.83	6-9	13.7	90	达标
2020/3/27	1:00:00	7.93	6-9	16.5	90	达标
2020/3/27	5:00:00	7.02	6-9	60.8	90	达标
2020/3/27	9:00:00	8.13	6-9	62.5	90	达标
2020/3/28	13:00:00	7.88	6-9	24.5	90	达标
2020/3/28	17:00:00	7.68	6-9	35.5	90	达标
2020/3/28	21:00:00	7.79	6-9	59.3	90	达标
2020/3/28	1:00:00	7.24	6-9	70.5	90	达标
2020/3/28	5:00:00	7.17	6-9	36.8	90	达标
2020/3/28	9:00:00	8.12	6-9	24	90	达标
2020/3/29	13:00:00	8.22	6-9	25.9	90	达标
2020/3/29	17:00:00	8.18	6-9	23.6	90	达标
2020/3/29	21:00:00	8.24	6-9	29.1	90	达标
2020/3/29	1:00:00	8.27	6-9	27.1	90	达标
2020/3/29	5:00:00	8.29	6-9	29.3	90	达标
2020/3/29	9:00:00	7.58	6-9	17.4	90	达标
2020/3/30	13:00:00	8.09	6-9	22.3	90	达标
2020/3/30	17:00:00	7.69	6-9	26.5	90	达标
2020/3/30	21:00:00	7.53	6-9	24.9	90	达标
2020/3/30	1:00:00	7.58	6-9	25.5	90	达标
2020/3/30	5:00:00	7.6	6-9	59.5	90	达标
2020/3/30	9:00:00	8.01	6-9	36.8	90	达标
2020/3/31	13:00:00	8.07	6-9	38.3	90	达标
2020/3/31	17:00:00	7.76	6-9	63	90	达标
2020/3/31	21:00:00	7.22	6-9	57	90	达标

2020/3/31	1:00:00	8.23	6-9	53.3	90	达标
2020/3/31	5:00:00	8.33	6-9	42.8	90	达标
2020/3/31	9:00:00	7.93	6-9	50	90	达标

广州科城环保科技有限公司污染源监测数据公开（手动监测）

监测日期：2020-3-16

监测项目	检测位点	单位	监测值	标准值	监测结果说明
总锌	生产废水总排口	mg/l	0.08	2	达标
石油类	生产废水总排口	mg/l	ND	5	达标
氰化物	生产废水总排口	mg/l	0.024	0.3	达标
总铜	生产废水总排口	mg/l	ND	0.5	达标
总锰	生产废水总排口	mg/l	0.03	2	达标
悬浮物	生产废水总排口	mg/l	6	60	达标
pH值	生产废水总排口	-	7.45	6-9	达标
氨氮 (NH ₃ -N)	生产废水总排口	mg/l	0.366	10	达标
五日生化需氧量	生产废水总排口	mg/l	3.8	20	达标
总铁	生产废水总排口	mg/l	0.22	-	达标
化学需氧量	生产废水总排口	mg/l	11	90	达标
氟化物 (以F ⁻ 计)	生产废水总排口	mg/l	ND	10	达标
阴离子表面活性剂	生产废水总排口	mg/l	0.136	5	达标
硫化物	生产废水总排口	mg/l	ND	0.58	达标
动植物油	生产废水总排口	mg/l	0.12	10	达标
挥发酚	生产废水总排口	mg/l	ND	0.3	达标
总汞	车间排放口-01	mg/l	<0.5	0.05	达标
	车间排放口-02	mg/l	<0.5	0.05	达标
总镉	车间排放口-01	mg/l	<0.1	0.1	达标
	车间排放口-02	mg/l	<0.1	0.1	达标
总铬	车间排放口-01	mg/l	<0.5	1.5	达标
	车间排放口-02	mg/l	<0.5	1.5	达标
六价铬	车间排放口-01	mg/l	0.009	0.5	达标
	车间排放口-02	mg/l	0.227	0.5	达标
总砷	车间排放口-01	mg/l	<0.5	0.5	达标
	车间排放口-02	mg/l	<0.5	0.5	达标
总铅	车间排放口-01	mg/l	<0.5	1	达标
	车间排放口-02	mg/l	<0.5	1	达标
总镍	车间排放口-01	mg/l	<0.5	1	达标
	车间排放口-02	mg/l	<0.5	1	达标