

广州科城环保科技有限公司污染源监测数据公开（在线自动监测）

监测点位名称：工业废水排放口

监测时间：2019年12月

监测时间		pH值	标准限值	化学需氧量 (mg/l)	标准限值 (mg/l)	监测结果说明
2019/12/1	1:00:00	8.34	6-9	14.1	90	达标
2019/12/1	5:00:00	8.44	6-9	8.9	90	达标
2019/12/1	9:00:00	8.38	6-9	22.4	90	达标
2019/12/1	13:00:00	8.21	6-9	19.9	90	达标
2019/12/1	17:00:00	8.17	6-9	25.1	90	达标
2019/12/1	21:00:00	8.27	6-9	29	90	达标
2019/12/2	1:00:00	8.33	6-9	30.3	90	达标
2019/12/2	5:00:00	8.37	6-9	32.3	90	达标
2019/12/2	9:00:00	8.4	6-9	34	90	达标
2019/12/2	13:00:00	8.42	6-9	34.8	90	达标
2019/12/2	17:00:00	8.4	6-9	71	90	达标
2019/12/2	21:00:00	7.05	6-9	45	90	达标
2019/12/3	1:00:00	7.42	6-9	74.5	90	达标
2019/12/3	5:00:00	7.71	6-9	69.5	90	达标
2019/12/3	9:00:00	7.52	6-9	43.5	90	达标
2019/12/3	13:00:00	7.6	6-9	66.5	90	达标
2019/12/3	17:00:00	7.71	6-9	65.5	90	达标
2019/12/3	21:00:00	7.66	6-9	57.3	90	达标
2019/12/4	1:00:00	7.8	6-9	53.3	90	达标
2019/12/4	5:00:00	8.31	6-9	86.5	90	达标
2019/12/4	9:00:00	7.87	6-9	74.5	90	达标
2019/12/4	13:00:00	8.1	6-9	60.5	90	达标
2019/12/4	17:00:00	7.29	6-9	75	90	达标
2019/12/4	21:00:00	7.84	6-9	32.3	90	达标
2019/12/5	1:00:00	7.87	6-9	14.9	90	达标
2019/12/5	5:00:00	6.7	6-9	51.3	90	达标
2019/12/5	9:00:00	8.17	6-9	50	90	达标
2019/12/5	13:00:00	7.74	6-9	53.5	90	达标
2019/12/5	17:00:00	8.15	6-9	52.5	90	达标
2019/12/5	21:00:00	8.18	6-9	47.5	90	达标
2019/12/6	1:00:00	7.85	6-9	59.5	90	达标
2019/12/6	5:00:00	8.24	6-9	50.5	90	达标
2019/12/6	9:00:00	8.11	6-9	60.8	90	达标
2019/12/6	13:00:00	8.25	6-9	51.8	90	达标
2019/12/6	17:00:00	7.78	6-9	56.8	90	达标
2019/12/6	21:00:00	7.72	6-9	57.8	90	达标
2019/12/7	1:00:00	8.66	6-9	11.3	90	达标
2019/12/7	5:00:00	8.08	6-9	65	90	达标
2019/12/7	9:00:00	8.77	6-9	6.9	90	达标
2019/12/7	13:00:00	8.34	6-9	7.2	90	达标
2019/12/7	17:00:00	7.79	6-9	10	90	达标
2019/12/7	21:00:00	7.49	6-9	80	90	达标

2019/12/8	1:00:00	7.69	6-9	41	90	达标
2019/12/8	5:00:00	7.16	6-9	29.3	90	达标
2019/12/8	9:00:00	7.55	6-9	35.8	90	达标
2019/12/8	13:00:00	7.45	6-9	25.9	90	达标
2019/12/8	17:00:00	7.71	6-9	15	90	达标
2019/12/8	21:00:00	7.81	6-9	17.8	90	达标
2019/12/9	1:00:00	7.92	6-9	14.3	90	达标
2019/12/9	5:00:00	7.64	6-9	18	90	达标
2019/12/9	9:00:00	8.08	6-9	14.3	90	达标
2019/12/9	13:00:00	7.52	6-9	70.5	90	达标
2019/12/9	17:00:00	7.72	6-9	63.8	90	达标
2019/12/9	21:00:00	7.15	6-9	45.5	90	达标
2019/12/10	1:00:00	7.97	6-9	43	90	达标
2019/12/10	5:00:00	8.14	6-9	56.8	90	达标
2019/12/10	9:00:00	8.34	6-9	41.5	90	达标
2019/12/10	13:00:00	8.41	6-9	41.3	90	达标
2019/12/10	17:00:00	8.11	6-9	24.5	90	达标
2019/12/10	21:00:00	7.62	6-9	60.3	90	达标
2019/12/11	1:00:00	7.35	6-9	32.3	90	达标
2019/12/11	5:00:00	7.36	6-9	23.8	90	达标
2019/12/11	9:00:00	7.36	6-9	24.4	90	达标
2019/12/11	13:00:00	7.84	6-9	30.6	90	达标
2019/12/11	17:00:00	6.7	6-9	49.3	90	达标
2019/12/11	21:00:00	7.03	6-9	22.5	90	达标
2019/12/12	1:00:00	7.47	6-9	43.3	90	达标
2019/12/12	5:00:00	7.26	6-9	12.9	90	达标
2019/12/12	9:00:00	7.79	6-9	43	90	达标
2019/12/12	13:00:00	7.67	6-9	67	90	达标
2019/12/12	17:00:00	6.76	6-9	42	90	达标
2019/12/12	21:00:00	7.26	6-9	47.3	90	达标
2019/12/13	1:00:00	7.98	6-9	45.3	90	达标
2019/12/13	5:00:00	8.12	6-9	70	90	达标
2019/12/13	9:00:00	7.87	6-9	24.6	90	达标
2019/12/13	13:00:00	7.9	6-9	0	90	达标
2019/12/13	17:00:00	7.92	6-9	0	90	达标
2019/12/13	21:00:00	7.94	6-9	0	90	达标
2019/12/14	1:00:00	7.97	6-9	0	90	达标
2019/12/14	5:00:00	8.01	6-9	0	90	达标
2019/12/14	9:00:00	8.05	6-9	0	90	达标
2019/12/14	13:00:00	8.09	6-9	0	90	达标
2019/12/14	17:00:00	8.12	6-9	0	90	达标
2019/12/14	21:00:00	8.17	6-9	0	90	达标
2019/12/15	1:00:00	8.2	6-9	0	90	达标
2019/12/15	5:00:00	8.24	6-9	0	90	达标
2019/12/15	9:00:00	8.27	6-9	0	90	达标
2019/12/15	13:00:00	8.3	6-9	0	90	达标

2019/12/15	17:00:00	8.33	6-9	0	90	达标
2019/12/15	21:00:00	8.36	6-9	0	90	达标
2019/12/16	1:00:00	8.39	6-9	0	90	达标
2019/12/16	5:00:00	8.41	6-9	0	90	达标
2019/12/16	9:00:00	8.43	6-9	0	90	达标
2019/12/16	13:00:00	8.27	6-9	12.3	90	达标
2019/12/16	17:00:00	7.57	6-9	52.8	90	达标
2019/12/16	21:00:00	7.68	6-9	39.5	90	达标
2019/12/17	1:00:00	7.63	6-9	63	90	达标
2019/12/17	5:00:00	7.71	6-9	37.3	90	达标
2019/12/17	9:00:00	7.48	6-9	39	90	达标
2019/12/17	13:00:00	8.2	6-9	39	90	达标
2019/12/17	17:00:00	8.2	6-9	39	90	达标
2019/12/17	21:00:00	8.2	6-9	39	90	达标
2019/12/18	1:00:00	8.21	6-9	39	90	达标
2019/12/18	5:00:00	8.27	6-9	39	90	达标
2019/12/18	9:00:00	8.3	6-9	39	90	达标
2019/12/18	13:00:00	8.23	6-9	18.5	90	达标
2019/12/18	17:00:00	7.69	6-9	38.8	90	达标
2019/12/18	21:00:00	7.68	6-9	28	90	达标
2019/12/19	1:00:00	8.3	6-9	18.8	90	达标
2019/12/19	5:00:00	7.84	6-9	45.8	90	达标
2019/12/19	9:00:00	8.22	6-9	19.5	90	达标
2019/12/19	13:00:00	8.29	6-9	85.1	90	达标
2019/12/19	17:00:00	8.48	6-9	31.5	90	达标
2019/12/19	21:00:00	8.44	6-9	41	90	达标
2019/12/20	1:00:00	8.26	6-9	87.5	90	达标
2019/12/20	5:00:00	8.31	6-9	74.5	90	达标
2019/12/20	9:00:00	8.05	6-9	56.8	90	达标
2019/12/20	13:00:00	8.14	6-9	57.3	90	达标
2019/12/20	17:00:00	8.3	6-9	22	90	达标
2019/12/20	21:00:00	7.89	6-9	36	90	达标
2019/12/21	1:00:00	7.82	6-9	39	90	达标
2019/12/21	5:00:00	7.67	6-9	44	90	达标
2019/12/21	9:00:00	7.64	6-9	34.5	90	达标
2019/12/21	13:00:00	7.65	6-9	38.5	90	达标
2019/12/21	17:00:00	7.69	6-9	60	90	达标
2019/12/21	21:00:00	7.72	6-9	38.8	90	达标
2019/12/22	1:00:00	7.6	6-9	40	90	达标
2019/12/22	5:00:00	7.3	6-9	39.5	90	达标
2019/12/22	9:00:00	7.12	6-9	38.5	90	达标
2019/12/22	13:00:00	7.97	6-9	14.2	90	达标
2019/12/22	17:00:00	8.09	6-9	0	90	达标
2019/12/22	21:00:00	8.29	6-9	21.4	90	达标
2019/12/23	1:00:00	8.43	6-9	9.8	90	达标
2019/12/23	5:00:00	8.44	6-9	0	90	达标

2019/12/23	9:00:00	8.46	6-9	0	90	达标
2019/12/23	13:00:00	8.48	6-9	0	90	达标
2019/12/23	17:00:00	8.48	6-9	0	90	达标
2019/12/23	21:00:00	7.92	6-9	3.9	90	达标
2019/12/24	1:00:00	7.97	6-9	10.7	90	达标
2019/12/24	5:00:00	7.98	6-9	11.3	90	达标
2019/12/24	9:00:00	8	6-9	0	90	达标
2019/12/24	13:00:00	8.04	6-9	0	90	达标
2019/12/24	17:00:00	8.04	6-9	0	90	达标
2019/12/24	21:00:00	7.88	6-9	7.5	90	达标
2019/12/25	1:00:00	7.79	6-9	39	90	达标
2019/12/25	5:00:00	7.75	6-9	43.8	90	达标
2019/12/25	9:00:00	7.88	6-9	43.5	90	达标
2019/12/25	13:00:00	8.17	6-9	78	90	达标
2019/12/25	17:00:00	7.86	6-9	55	90	达标
2019/12/25	21:00:00	8.24	6-9	49.8	90	达标
2019/12/26	1:00:00	7.87	6-9	63.8	90	达标
2019/12/26	5:00:00	7.87	6-9	48	90	达标
2019/12/26	9:00:00	7.89	6-9	31.5	90	达标
2019/12/26	13:00:00	8.09	6-9	59.8	90	达标
2019/12/26	17:00:00	7.58	6-9	31.6	90	达标
2019/12/26	21:00:00	7.82	6-9	45.5	90	达标
2019/12/27	1:00:00	8.15	6-9	66	90	达标
2019/12/27	5:00:00	7.81	6-9	71	90	达标
2019/12/27	9:00:00	8.23	6-9	69	90	达标
2019/12/27	13:00:00	7.69	6-9	26.5	90	达标
2019/12/27	17:00:00	7.73	6-9	37	90	达标
2019/12/27	21:00:00	8.45	6-9	67.5	90	达标
2019/12/28	1:00:00	8.64	6-9	69	90	达标
2019/12/28	5:00:00	8.33	6-9	10.6	90	达标
2019/12/28	9:00:00	8.89	6-9	3.8	90	达标
2019/12/28	13:00:00	8.73	6-9	41	90	达标
2019/12/28	17:00:00	8.9	6-9	7	90	达标
2019/12/28	21:00:00	8.23	6-9	39.8	90	达标
2019/12/29	1:00:00	8.55	6-9	55	90	达标
2019/12/29	5:00:00	8.43	6-9	48	90	达标
2019/12/29	9:00:00	8.48	6-9	46.3	90	达标
2019/12/29	13:00:00	8.03	6-9	20.9	90	达标
2019/12/29	17:00:00	7.98	6-9	13.9	90	达标
2019/12/29	21:00:00	7.97	6-9	28.6	90	达标
2019/12/30	1:00:00	7.42	6-9	61.5	90	达标
2019/12/30	5:00:00	8.24	6-9	81	90	达标
2019/12/30	9:00:00	8.46	6-9	56.3	90	达标
2019/12/30	13:00:00	8.45	6-9	44.3	90	达标
2019/12/30	17:00:00	8.23	6-9	17.3	90	达标
2019/12/30	21:00:00	8.09	6-9	20.3	90	达标

2019/12/31	1:00:00	8.06	6-9	23.1	90	达标
2019/12/31	5:00:00	7.33	6-9	65.5	90	达标
2019/12/31	9:00:00	7.85	6-9	75.5	90	达标
2019/12/31	13:00:00	7.99	6-9	70.5	90	达标
2019/12/31	17:00:00	7.92	6-9	67.5	90	达标
2019/12/31	21:00:00	7.4	6-9	54.5	90	达标

广州科城环保科技有限公司污染源监测数据公开（手动监测）

监测日期：2019-12-17

监测项目	单位	监测值	标准值	监测结果说明
总铜	mg/l	<0.5	0.5	达标
总镍	mg/l	<0.5	0.5	达标
总锌	mg/l	<0.5	20	达标
总锰	mg/l	<0.5	20	达标
COD	mg/l	64.2	90	达标
氨氮	mg/l	<10	10	达标
总磷	mg/l	<0.5	0.5	达标
总氰化物	mg/l	<0.2	0.3	达标
BOD	mg/l	5.73	20	达标
悬浮物	mg/l	2.5	60	达标
氟化物	mg/l	1.33	10	达标
挥发酚	mg/l	0.02	0.3	达标
硫化物	mg/l	ND	0.5	达标
石油类	mg/l	0.25	5	达标
动植物油	mg/l	0.34	10	达标
阴离子表面活性剂	mg/l	0.116	5	达标